

DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by D.Punnaivanam, Block Health Supervisor (Name of Officer with designation) Govt Primary Health Centre, Chokkampatti, Kadayanallur Taluk of Tenkasi District of Tamilnadu inspected the DANALAKSHMI INTERNATIONAL SCHOOL, at SF No 292/6, 7A., Main Road, Chokkampatti Village, Punnaiyapuram, Kadayanallur Taluk of TENKASI DISTRICT (Name and address of the School) on 10.05.2025 (Date of inspection) and on the basis of water Testing report (attached being R.No.407/L/2025/M.11/CWA/Tvl. Dated -5-2025 of the Chief water Analyst, Regional Public Health water Analysis laboratory, Tirunelveli-627011) certified that the DANALAKSHMI INTERNATIONAL SCHOOL has Safe Drinking water facilities for the student and members of the staffs of the Institution. School is also maintaining the hygienic condition in the school building and the campus as per norms prescribed by the Central/State/UT Govt.

This certificate is valid up to 09-05-2026 (one year from the date of issue)

D. Punnaivanam 10/5/2025
BLOCK HEALTH SUPERVISOR
Govt. Primary Health Centre
Chokkampatti - 627751
Kadayanallur Block

Name: D.Punnaivanam

Designation: Block Health Supervisor

Name and address of the Department: Govt Primary Health Centre

Chokkampatti

Kadayanallur Taluk

Place: Kadayanallur

Date: 10-05-2025

To

The Chairman

DANALAKSHMI INTERNATIONAL SCHOOL,
SF No 292/6, 7A., Main Road, Chokkampatti Village,
Punnaiyapuram, Kadayanallur Taluk, Tenkasi District

PRINCIPAL
DANALAKSHMI INTERNATIONAL SCHOOL
292/6, 7A, PUNNAIYAPURAM,
KADAYANALLUR (T.K), TENKASI (DT) - 627 855.



DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
REGIONAL PUBLIC HEALTH WATER ANALYSIS LABORATORY, TIRUNELVELI-11

From
Thiru.D.Asir Selvaraj B.Sc., B.Ed.,
Chief Water Analyst ,
Regional Public Health Water
Analysis Laboratory,
Tirunelveli - 627 011.

To
The Chairman,
Danalakshmi International School (CBSE),
S.F.NO 292/6, 7A, Punnaiyapuram,
Kadayanallur Taluk,
Tenkasi District- 627 855.

R.No: 407/L/2025/M.11/CWA/Tvl., Dated: .05.2025

Sir / Madam,


Sub: Report on Examination of water sample from Danalakshmi International school (CBSE), S.F.No.292/6, 7A, Punnaiyapuram, Kadayanallur Taluk, Tenkasi district collected on 06.05.2025.

A sample of water stated to have been collected on 06.05.2025 from the R.O water near stair case ground floor at Danalakshmi International school (CBSE), S.F.No.292/6, 7A, Punnaiyapuram, Kadayanallur Taluk, Tenkasi district (Source: Bore well) by Mr.R.Thirumalaikumar, Chairman, was received at this laboratory on 07.05.2025 from the addressee to assess its suitability for drinking purpose.

The results of analysis are furnished overleaf.

The sample of water is colorless and clear in physical appearance.

Judged by the results of analysis it is of satisfactory chemical and bacteriological quality for drinking.


Chief Water Analyst,
Regional Public Health Water Analysis
Laboratory, Tirunelveli-11.

Copy to: Lab & File.


PRINCIPAL
DANALAKSHMI INTERNATIONAL SCHOOL
292/6, 7A, PUNNAIYAPURAM,
KADAYANALLUR (T.K), TENKASI (DT) - 627 855.

DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
REGIONAL PUBLIC HEALTH WATER ANALYSIS LABORATORY, TIRUNELVELI-11
RESULTS OF EXAMINATION OF SAMPLES OF WATER

Samples from :	Danalakshmi International School, S.F.NO.292/6, 7A, Punnaiyapuram, Kadayanallur (Taluk), Tenkasi District			
Collected by :	Mr.R.Thirumalaikumar, Chairman			
Date of collection :	06.05.2025			
Date of Receipt :	07.05.2025			
	M-11			
Source as per label (Bore well)	R.O water near stair case ground floor			
Bacteriological Examination				
Plate count per ml.on agar at 37°C	20			
MPN of Coliform bacteria/100 ml	0			
Rapid test for E.Coli-I				
Results of Vibrio test				
Physical Examination				
Colour	Colourless			
Turbidity (NTU)	5			
Smell	None			
Chemical Examination (in mg/l)				
Total Dissolved solids	50			
Carbonate Hardness (as CaCO ₃)	10			
Non-carbonate Hardness(as CaCO ₃)	23			
Total Hardness (as CaCO ₃)	33			
Calcium Hardness (as CaCO ₃)	10			
Magnesium Hardness (as CaCO ₃)	23			
Chloride (as Cl)	12			
Ammoniacal Nitrogen (as N)	-			
Albuminoid Nitrogen (as N)	-			
Oxygen absorbed (Tidys test)	0.16			
Nitrate Nitrogen	0			
Acidity/Akalinity} Phenolphthalein as CaCO ₃ } Methyl Orange	0 10			
Fluoride (as F)	0.1			
pH value	6.5			
Total Iron (as Fe)	0.05			
Manganese (as Mn)				
Qualitative Tests:				
Nitrite Nitrogen	Trace			
Sulphate	Trace			
Phosphate	Trace			
Toxic Substance				
Electrical conductivity(Reciprocal megohms per cm at 20°C)	70			
Microscopical Examination	Amorphous Matter			



DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
REGIONAL PUBLIC HEALTH WATER ANALYSIS LABORATORY, TIRUNELVELI-11

From Thiru.D.Asir Selvaraj B.Sc., B.Ed., Chief Water Analyst , Regional Public Health Water Analysis Laboratory, Tirunelveli - 627 011. To The Chairman, Danalakshmi International School (CBSE), S.F.NO 292/6, 7A, Punnaiyapuram, Kadayanallur Taluk, Tenkasi District- 627 855.

R.No: 407/L/2025/M.11/CWA/Tvl., Dated: 05.2025

Sir / Madam,

Sub: Report on Examination of water sample from Danalakshmi International school (CBSE), S.F.No.292/6, 7A, Punnaiyapuram, Kadayanallur Taluk, Tenkasi district collected on 06.05.2025.

A sample of water stated to have been collected on 06.05.2025 from the R.O water near stair case ground floor at Danalakshmi International school (CBSE), S.F.No.292/6, 7A, Punnaiyapuram, Kadayanallur Taluk, Tenkasi district (Source: Bore well) by Mr.R.Thirumalaikumar, Chairman, was received at this laboratory on 07.05.2025 from the addressee to assess its suitability for drinking purpose.

The results of analysis are furnished overleaf.

The sample of water is colorless and clear in physical appearance.

Judged by the results of analysis it is of satisfactory chemical and bacteriological quality for drinking.

Seamin 15-5-2022
Chief Water Analyst,
Regional Public Health Water Analysis
Laboratory, Tirunelveli-11.

Copy to: Lab & File.

DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
REGIONAL PUBLIC HEALTH WATER ANALYSIS LABORATORY, TIRUNELVELI-11
RESULTS OF EXAMINATION OF SAMPLES OF WATER

Samples from :	Danalakshmi International School, S.F.NO.292/6, 7A, Punnaiyapuram, Kadayanallur (Taluk), Tenkasi District				
Collected by :	Mr.R.Thirumalaikumar, Chairman				
Date of collection :	06.05.2025				
Date of Receipt :	07.05.2025				
	M-11				
Source as per label (Bore well)	R.O water near stair case ground floor				
Bacteriological Examination					
Plate count per ml.on agar at 37°C	20				
MPN of Coliform bacteria/100 ml	0				
Rapid test for E.Coli-I					
Results of Vibrio test					
Physical Examination					
Colour	Colourless				
Turbidity (NTU)	5				
Smell	None				
Chemical Examination (in mg/l)					
Total Dissolved solids	50				
Carbonate Hardness (as CaCO ₃)	10				
Non-carbonate Hardness(as CaCO ₃)	23				
Total Hardness (as CaCO ₃)	33				
Calcium Hardness (as CaCO ₃)	10				
Magnesium Hardness (as CaCO ₃)	23				
Chloride (as Cl)	12				
Ammoniacal Nitrogen (as N)	-				
Albuminoid Nitrogen (as N)	-				
Oxygen absorbed (Tidys test)	0.16				
Nitrate Nitrogen	0				
Acidity/Aalkalinity} Phenolphthalein as CaCO ₃ } Methyl Orange	0 10				
Fluoride (as F)	0.1				
pH value	6.5				
Total Iron (as Fe)	0.05				
Manganese (as Mn)					
Qualitative Tests:					
Nitrite Nitrogen	Trace				
Sulphate	Trace				
Phosphate	Trace				
Toxic Substance					
Electrical conductivity(Reciprocal megohms per cm at 20°C)	70				
Microscopical Examination	Amorphous Matter				